

# City of San Diego

CITY CONTACT: Brittany Friedenreich, Senior Contract Specialist, Email: [BFriedenreic@sandiego.gov](mailto:BFriedenreic@sandiego.gov)  
Phone No. (619) 533-3104

---

## ADDENDUM B



## FOR

## JOHN F. KENNEDY NEIGHBORHOOD PARK RESTROOM AND PLAYGROUND IMPROVEMENTS

BID NO.:	<u>K-23-2101-DBB-3</u>
SAP NO. (WBS/IO/CC):	<u>B-18005</u>
CLIENT DEPARTMENT:	<u>1714</u>
COUNCIL DISTRICT:	<u>4</u>
PROJECT TYPE:	<u>GB</u>
CDBG NO.:	<u>100003-2022</u>

---

### **BID DUE DATE:**

**2:00 PM**  
**JANUARY 26, 2023**

**CITY OF SAN DIEGO'S ELECTRONIC BIDDING SITE, PLANETBIDS**

<http://www.sandiego.gov/cip/bidopps/index.shtml>

**A. CHANGES TO CONTRACT DOCUMENTS**

The following changes to the Contract Documents are hereby made effective as though originally issued with the bid package. Bidders are reminded that all previous requirements to this solicitation remain in full force and effect.

**B. BIDDER'S QUESTIONS**

Q1. If the existing sod is damaged during the irrigation replacement process, does it need to be replaced or it can be repair by hydroseeding.

A1. Damaged sod shall be repaired with Tifway Bermuda sod per Whitebook Section 801-4.8.3 Sod.

Q2. Also can you clarify the color of concrete the city wants for mowing strip and curb A and curb B?

A2. Mowing strips and curbs A and B shall be integrally colored with Davis 'San Diego Buff' per SSP Section 201-1.2.4 Chemical Admixture

Rania Amen, Director  
Engineering & Capital Projects Department

Dated: *January 18, 2023*  
San Diego, California

RA/AP/br