



Grossmont-Cuyamaca Community College District

CUYAMACA COLLEGE AUTO LIFTS REPLACEMENT B26.014

Q&A Deadline October 1, 2026 4:00 PM (PDT)

Set 1 Released via Addendum 04 10/06/2026 1:23 PM (PDT) – 12 questions

1.1 Do any man doors recieve paint finish, the door schedule lists all as FF

Answer Yes, all man doors to receive new paint. Paint to be "Blue Beethoven Blue".

1.2 Will there be any roof penetrations, if so will details be provided

Answer No roof penetrations are required.

1.3 No detail is shown for the duablock roof supports for the electrical will one be provided

Answer Provide durablock supports and install per manufacturer's installation requirements.

1.4 there are no details for patching at the removed parking signage, will there be patching needed for this

Answer Yes, asphalt paving patching will be required for removal of existing post signs.

1.5 Where is the existing outlet in the men's restroom being relocated to

Answer Coordinate location with District. Extend conduit/conductors as required.

1.6 What restroom accessories are being replaced

Answer Lavatory with faucet and adding new surface mounted toilet tissue dispenser and surface mounted feminine napkin disposal. Refer to detail 3/A-1.4

1.7 Is the existing drinking fountain being replaced

Answer No.

1.8 SPDs listed in Panelboard specs. Confirming if Panelboard EV requires them.

Answer Yes, SPD is required at the panelboard.

1.9 Section 26-24-16, state 208V panels are 10k AIC min. No AIC rating noted on the plans for Panelboard EV. Please confirm the rating.

Answer Exact rating shall be short circuit and coordination study. Refer to panelboard spec.

1.10 Section 26-22-23, Will you accept transformers with "Hammond" label. They make Siemens and GE transformers.

Answer It is acceptable provided that it meets all requirements listed in the construction documents.

1.11 Confirm Switchboard "SP" AIC Rating

Answer Contractor shall field verify. Note that the new 225A/3P breaker feeding transformer 'T-EV' shall be installed in switchboard 'P'. See forthcoming Addendum 05 (DSA Delta 2) for changes to the one line.

1.12 The specs have hardware descriptions, but no sets. The door schedule shows Set #1 for opening #K108BD and Set #3 for Opening #K108C. It's listed Set #1 & #3 for the panic hardware and hardware groups for each opening. Without sets or manufacturers, every door company will be bidding different manufacturers, finishes, sizes, types, etc.... The pricing will fluctuate. Please provide the specified information.

Answer This information is provided in section 08 06 71 - 3, please note the links to the cut sheets.



Search & Bid on Thousands of Contracts

www.vendorline.com

