

GENERAL

- ALL FACILITIES SHALL BE ACCESSIBLE FOR THE PHYSICALLY HANDICAPPED PER CDR (CAG) TITLE 24, THE AMERICANS WITH DISABILITIES ACT, TITLE 2 AND 10646 (ANSI).
- ALL PRIMARY ENTRANCES SHALL BE ACCESSIBLE.
- HAZARDS:
 - HEADROOM OF 80" MIN. SHALL BE MAINTAINED FOR WALKS, CORRIDORS, AISLES, ETC.
 - OBJECTS WITH PROTRUDING EDGES BELOW 27" ABOVE FINISHED FLOOR MAY PROTRUDE ANY AMOUNT.
 - PROTRUDING OBJECTS ON FLOORS BETWEEN 27" AND 48" ABOVE FINISHED FLOOR SHALL BE INSTALLED AT A MAXIMUM OF 1/2".
 - HAZARD CHANGES IN LEVEL EXCEEDING 4" ADJACENT TO WALKS, EXCEPT BETWEEN WALKS AND ADJACENT STREETS OR DRIVEWAYS, SHALL BE IDENTIFIED BY 6" HIGH WARNING CURBS AROUND WALK SURFACE.

- ELECTRICAL REQUIREMENTS:
 - 2, 3, AND 30 AMP RECEPTACLE OUTLETS SHALL BE INSTALLED BETWEEN 18" AND 24" ABOVE THE FLOOR.
 - CENTER OF SWITCH SHALL BE LOCATED NOT LESS THAN 30" NOR MORE THAN 48" ABOVE THE FLOOR.

ENTRANCES, EXITS, DOORS & AREAS FOR EVACUATION ASSISTANCE

- ALL ENTRANCES AND ALL EXTERIOR GROUND FLOOR EXIT DOORS TO BUILDINGS AND FACILITIES SHALL BE MADE ACCESSIBLE TO PERSONS WITH DISABILITIES. SEC. 1108.2.1.
- REVOLVING DOORS SHALL NOT BE USED AS A REQUIRED ENTRANCE FOR PERSONS WITH DISABILITIES. SEC. 1108.2.2.3.
- DURING PERIODS OF PARTIAL OR RESTRICTED USE OF A BUILDING OR FACILITY, THE ENTRANCES USED FOR PRIMARY ACCESS SHALL BE ACCESSIBLE AND USABLE FOR PERSONS WITH DISABILITIES. SEC. 1108.1.1.2.
- ALL GATES, INCLUDING TICKET GATES, SHALL MEET ALL APPLICABLE ACCESSIBILITY SPECIFICATIONS AT DOORS. SEC. 1108.2.1.4.
- LATCHING AND LOCKING DOORS THAT ARE HAND-ACTIVATED AND WHICH ARE IN A PATH OF TRAVEL SHALL BE OPERABLE WITH A SINGLE EFFORT BY LEVEL TYPE HANDWARE, PIANO BARS, PUSH/PULL ACTIVATING BARS, OR OTHER HARDWARE DESIGNATED TO PROVIDE PASSAGE WITHOUT REQUIRING THE ABILITY TO GRASP THE OPENING HARDWARE. LOCKED EXIT DOORS SHALL OPERATE AS ABOVE IN EMERGENCY SITUATIONS. SEC. 1004.1.1.

- HAND-ACTIVATED DOOR OPENING HARDWARE SHALL BE CENTERED BETWEEN 36" AND 48" ABOVE THE FLOOR. SEC. 1108.2.2.2.

- EVERY DOORWAY WHICH IS LOCATED WITHIN AN ACCESSIBLE PATH OF TRAVEL SHALL BE OF A SIZE AS TO PERMIT THE INSTALLATION OF A DOOR NOT LESS THAN 34" WIDE AND NOT LESS THAN 6' 8" HIGH. WHEN INSTALLED, EXIT DOORS SHALL BE CAPABLE OF OPENING SO THAT THE CLEAR WIDTH OF THE EXIT IS NOT LESS THAN 32". SEC. 1004.6.1, FIG. 1103.1 & 1103.2.

- FOR HINGED DOORS, THE OPENING WIDTH SHALL BE MEASURED WITH THE DOOR POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION. SEC. 1103.2.3.

- WHERE A PAIR OF DOORS IS UTILIZED, AT LEAST ONE OF THE DOORS SHALL PROVIDE A CLEAR, UNOBSTRUCTED OPENING WIDTH OF 32" WITH THE LEAF POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION. SEC. 1103.2.1.

- WHEN AN AUTOMATIC DOOR OPERATOR IS UTILIZED TO OPERATE A PAIR OF DOORS AT LEAST ONE OF THE DOORS SHALL PROVIDE A CLEAR, UNOBSTRUCTED OPENING WIDTH OF 32" WITH THE LEAF POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION. SEC. 1103.2.2.

- MINIMUM MANEUVERING CLEARANCES AT DOORS SHALL BE AS SHOWN IN FIGURE 1103.2A AND 1103.2B. THE FLOOR OR GROUND AREA WITHIN THE REQUIRED CLEARANCES SHALL BE LEVEL AND CLEAR. SEC. 1103.2.2.2.

- THERE SHALL BE A LEVEL, CLEAR FLOOR OF LANDING ON EACH SIDE OF A DOOR. THE LEVEL AREA SHALL HAVE A LENGTH IN THE DIRECTION OF DOOR SWING OF AT LEAST 6' AND THE LENGTH OPPOSITE THE DIRECTION OF DOOR SWING OF 4' AS MEASURED AT RIGHT ANGLE TO THE PLANE OF THE DOOR IN ITS CLOSED POSITION. SEC. 1103.2.2.2.

- WHERE THE DOOR OPENS INTO A STAIR OF A SMOKE-PROOF ENCLOSURE, THE LANDING NEED NOT HAVE A LENGTH OF 6' SEC. 1004.2.2A.

- THE WIDTH OF THE LEVEL AREA ON THE SIDE TO WHICH THE DOOR SWINGS SHALL EXTEND A MAXIMUM OF 24" PAST THE SWING EDGE OF THE DOOR FOR EXTERIOR DOORS AND A MAXIMUM OF 18" PAST THE SWING EDGE FOR INTERIOR DOORS. ADDITIONAL 12" IS REQUIRED AT THE PUSH SIDE. IF DOOR IS EQUIPPED WITH BOTH LATCH AND CLOSURE, SEC. 1103.2.2.3.

- THE FLOOR OR LANDING SHALL BE NOT MORE THAN 1" LOWER THAN THRESHOLD OF THE DOORWAY. SEC. 1103.2.2.4.1. EXISTING STAIRWAYS WHERE THERE IS NO LANDING, DOORS SHALL BE CONSPICUOUSLY MARKED WITH A SIGN READING: "DANGER: STAIRWAY AND LANDING CONEQUALENT HOPPING AND TRIPPING HAZARD. SEC. 1004.2.2.4.2.

- THE SPACE BETWEEN TWO CONSECUTIVE DOOR OPENINGS IN A VESTIBULE, SERVING OTHER THAN A REQUIRED EXIT STAIRWAY, SHALL PROVIDE A MINIMUM OF 48" OF CLEAR SPACE FROM ANY DOOR OPENING INTO SUCH VESTIBULE. IF THE DOOR IS POSITIONED AT AN ANGLE OF 90 DEGREES FROM ITS CLOSED POSITION, DOORS IN A SERIES SHALL SWING EITHER IN THE SAME DIRECTION OR AWAY FROM THE SPACE BETWEEN THE DOORS. SEE FIGURES 1103.2A FOR DESIGN ALTERNATIVES. SEC. 1103.2.2.5.

- THE BOTTOM 18" OF ALL DOORS EXCEPT AUTOMATIC AND SLIDING SHALL HAVE A SMOOTH, UNINTERRUPTED SURFACE TO ALLOW THE DOOR TO BE OPENED BY A WHEELCHAIR FOOTREST WITHOUT CREATING A TRAP OR HAZARDOUS CONDITION. WHERE NARROW FRAME DOORS ARE USED, A 10" HIGH SMOOTH FRAME SHALL BE INSTALLED ON THE PUSH SIDE OF THE DOOR. WHICH WILL ALLOW THE DOOR TO BE OPENED BY A WHEELCHAIR FOOTREST WITHOUT CREATING A TRAP OR HAZARDOUS CONDITION. SEC. 1103.2.2.6.

- MAXIMUM EFFORT TO OPERATE DOORS SHALL NOT EXCEED 5 POUNDS FOR EXTERIOR DOORS, AND FIVE POUNDS FOR INTERIOR DOORS, SUCH PULL OR PUSH EFFORT BEING APPLIED AT RIGHT ANGLES TO HINGED DOORS AND AT THE CENTER PLANE OF SLIDING OR FOLDING DOORS. CONTRASTING COLORS OR AUTOMATIC DOOR OPERATORS MAY BE UTILIZED TO MEET THE ABOVE STANDARDS. WHEN FIRE DOORS ARE REQUIRED, THE MAXIMUM EFFORT TO OPERATE THE DOOR MAY BE INCREASED TO THE MAXIMUM ALLOWABLE BY THE APPROPRIATE ADMINISTRATIVE AUTHORITY, NOT TO EXCEED 5 POUNDS. SEC. 1103.2.2.7.

- ALL RATED DOORS SHALL BE POSITIVE LATCHING AND SELF-CLOSING.

- "LABEL" SHALL MEAN "FIRE ASSEMBLY" AS DEFINED IN CFC 1002.2.

- ALL 20" WIDE RATED ASSEMBLIES SHALL BE PROVIDED WITH A FIRE-RESISTANT MATERIAL, SO INSTALLED TO PROVIDE AS SEAL WHERE THE DOOR MEETS THE STOP ON BOTH SIDES AND ACROSS THE TOP.

- PROVIDE A TACTILE SIGN WITH THE WORDS "EXIT" OUT AT EACH EXIT DOOR THAT LEADS DIRECTLY TO A GRADE-LEVEL EXTERIOR EXIT BY MEANS OF AN EXIT ENCLOSURE OR AN EXIT PASSAGEWAY. CBC SEC. 1002.2.6.1.

- PROVIDE A TACTILE SIGN WITH THE WORDS, "EXIT OUT" AT EACH EXIT ACCESS DOOR FROM AN INTERIOR ROOM OR AREA TO A CORRIDOR OR HALLWAY THAT IS REQUIRED TO HAVE A VISUAL EXIT SIGN. CBC SEC. 1002.2.6.1.

- FOR A DOOR WITH CLOSERS, THE SLOWEST OPEN FROM A 90 DEGREE OPEN POSITION TO 10 DEGREES FROM THE AREA SHALL BE AT LEAST 3 SECONDS. CBC 1103.2.2.1.

- STAIRWAYS AND HANDRAILS

- STAIRWAYS SHALL HAVE HANDRAILS ON EACH SIDE, AND EVERY STAIRWAY REQUIRED TO BE MORE THAN 66" IN WIDTH SHALL BE PROVIDED WITH NOT LESS THAN ONE INTERMEDIATE HANDRAIL FOR EACH 66" OF REQUIRED WIDTH. INTERMEDIATE HANDRAILS SHALL BE SPACED APPROXIMATELY EQUALLY ACROSS THE ENTIRE WIDTH OF THE STAIRWAY. SEC. 1003.1A.

- HANDRAILS SHALL BE 34" TO 38" ABOVE THE NOSING OF THE TREADS. SEC. 1006.2.1A & FIG. 1103.3.

- HANDRAILS SHALL EXTEND A MINIMUM OF 12" BEYOND THE TOP NOSING AND 12" PLUS THE TREAD WIDTH BEYOND THE BOTTOM NOSING. SEC. 1006.2.2A AND FIG. 1103.3 & 1103.3.1.

- WHERE THE EXTENSION OF THE HANDRAIL IN THE DIRECTION OF THE STAIR RUN WOULD CREATE A HAZARD, THE TERMINATION OF THE EXTENSION SHALL BE MADE EITHER HORIZONTAL OR TURNED SHOOTING TO THE FLOOR, WALL OR POST. WHERE THE STAIRS ARE CONTINUOUS FROM LANDING TO LANDING, THE INNER RAIL SHALL BE CONTINUOUS AND NEED NOT EXTEND INTO THE LANDING. SEC. 1006.2.2A & FIG. 1103.3.

- ENDS SHALL BE RETURNED OR TERMINATE IN NEVEL POSTS ON SAFETY LIFT. SEC. 1006.2.2A.

- HANDRAILS PROJECTING FROM A WALL SHALL HAVE A SPACE OF 1-1/2" BETWEEN THE WALL AND THE HANDRAIL. HANDRAILS MAY BE LOCATED IN A RECESS IF THE RECESS IS A MAXIMUM OF 2" DEEP AND EXTENDS AT LEAST 18" ABOVE THE TOP OF THE RAIL. HANDRAILS SHALL NOT INTERFERE WITH THEIR FITTINGS. SEC. 1006.2.2A & FIG. 1103.3.

- THE HANDRAIL PORTION OF HANDRAILS SHALL BE NOT LESS THAN 1-1/2" NOR MORE THAN 1-1/2" INCHES IN CROSS SECTIONAL NOMINAL DIMENSION ON THE SHAPE SHALL PROVIDE AN EQUIVALENT OPENING SURFACE. SEC. 1006.2.2A.1.

- PROVIDE HANDRAILS DESIGNED TO PROVIDE A GRASPING SURFACE TO AVOID THE PERSON FROM FALLING, THE SPACING OF BRACKETS SHALL NOT EXCEED 6 FEET AND THE ATTACHMENT SHALL BE CAPABLE OF WITHSTANDING A LOAD OF AT LEAST 200 POUNDS APPLIED IN ANY DIRECTION AT ANY POINT ON THE RAIL.

- MAINTAIN A SPACE OF 1-1/2" SPACE BETWEEN THE WALL AND THE RAIL FOR HANDRAILS PROJECTING FROM A WALL. SECTION 1006.2. HANDRAILS MAY BE LOCATED IN A RECESS MAXIMUM 2" DEEP EXTENDING AT LEAST 18" ABOVE THE TOP OF THE RAIL. (SEE EXCEPTION TYPES 45, 46 & 8).

- PROVIDE APPROVED STAIR IDENTIFICATION SIGNS IN RAISED BRASS MATERIALS AND RAISED BRASS SYMBOLS WHICH CONFORM TO SECTION 11178.5.2 AT EACH FLOOR LEVEL. FOR BUILDINGS TWO OR MORE STORIES IN HEIGHT, SECTION 1006.2.2A.1. THE SIGN SHALL IDENTIFY STAIRWAY, INDICATE WHETHER THERE IS ROOF ACCESS, THE FLOOR LEVEL, AND THE UPPER AND LOWER LEVEL. TERMINUS OF THE STAIRWAY. LOCATE THE SIGN APPROXIMATELY 5 FEET ABOVE THE FLOOR LANDING. IMMEDIATELY ADJACENT TO THE DOOR ON THE STAIRSIDE. RAISED BRASS SYMBOLS CONFORMING TO GRADE 2 SHALL BE USED WHEREVER BRASS SYMBOLS ARE SPECIFICALLY REQUIRED IN OTHER PORTIONS OF THE TITLE IN STANDARDS. DOTS SHALL BE 1/16 INCH IN SIZE ON CENTER IN EACH CELL WITH 6 INCH (150MM) SPACE BETWEEN CELLS. DOTS SHALL BE RAISED A MINIMUM OF 1/4 INCH (6.35MM) ABOVE THE BACKGROUND.

- MARK THE UPPER APPROACH AND THE LOWER TREAD OF EACH STAIR BY A STRIP OF CLEARLY CONTRASTING COLOR AT LEAST 3" WIDE AND PLACED PARALLEL TO AND NOT MORE THAN 1" FROM THE NOSING OF THE STAIR LANDING. THE STRIP SHALL BE AS L.P. RESISTANT AS THE OTHER TREADS OF THE STAIR.

- FOR STAIRS THAT OCCUR OUTSIDE THE BUILDING, MARK THE UPPER APPROACH AND ALL TREADS AS NOTED IN ITEM 11 ABOVE.

- PROVIDE TREAD SURFACES THAT ARE SLP FINISH WITH ROUNDED OR CHAMFERED EXPOSED EDGES AND NO AIRLIFT EDGES AT THE NOSING.

- MAINTAIN NOSING PROJECTION TO MORE THAN 1/32" PAST THE FACE OF THE RISER BEHIND 15.

- PROVIDE RISERS THAT ARE SUFFICIENTLY SOLID TO PREVENT THE PASSAGE OF OBJECTS LARGER

SANITARY FACILITIES

A. GENERAL

- SANITARY FACILITIES THAT SERVE BUILDINGS, FACILITIES OR PORTIONS OF BUILDINGS OR FACILITIES THAT ARE REQUIRED TO BE ACCESSIBLE TO PERSONS WITH DISABILITIES ARE REQUIRED TO BE ACCESSIBLE. SEC. 1108.1.1.

- WHERE SEPARATE FACILITIES ARE PROVIDED FOR NONHANDICAPPED PERSONS OF EACH SEX, SEPARATE FACILITIES SHALL BE PROVIDED FOR PERSONS WITH DISABILITIES OF EACH SEX ALSO. WHERE UNSEX FACILITIES ARE PROVIDED FOR PERSONS WITH DISABILITIES WITH CLOSE PROXIMITY TO THE NONACCESSIBLE FACILITY. SEC. 1108.2.

- DOORWAYS LEADING TO MEN'S SANITARY FACILITIES SHALL BE IDENTIFIED BY AN EQUIVALENT TRIANGLE 1" THICK WITH EDGES 1/2" LONG AND A VERTICA POINT UPWARD. WOMEN'S SANITARY FACILITIES SHALL BE IDENTIFIED BY A CIRCLE 1" THICK AND 12" IN DIAMETER. SEC. 1108.5.

- GEOMETRIC (CIRCLE AND TRIANGLE) SYMBOLS FOR SANITARY FACILITIES DOORS SHALL BE CENTERED ON THE DOOR AT A HEIGHT OF 60" AND THEIR COLOR AND CONTRAST SHALL BE DISTINCTLY DIFFERENT FROM THE COLOR AND CONTRAST OF THE DOOR. SEC. 1108.5.1.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3.

- ADDITIONAL SIGNAGE REQUIREMENTS: RAISED LETTERS SHALL BE PROVIDED AND SHALL BE ACCOMPANIED BY BRAILLE IN CONFORMANCE WITH SECTION 1108.5.1.1. OBJECTS OR SIGNS SHALL BE SANS SERIF UPPERCASE CHARACTERS ACCOMPANIED BY GRADE 2 BRAILLE COMPLYING WITH 1178.5.2. THEY SHALL BE INSTALLED ON THE WALL ADJACENT TO THE LATCH OUTSIDE OF THE DOOR. WHERE THERE IS NO WALL SPACE ON THE LATCH SIDE INCLUDING AT DOUBLE LEAF DOORS, SIGNS SHALL BE PLACED ON THE NEAREST ADJACENT WALL. PRESENTLY ON THE RIGHT. MOUNTING LOCATION SHALL BE DETERMINED SO THAT A PERSON MAY APPROACH WITHIN 12 INCHES OF SIGNAGE WITHOUT ENCOUNTERING PROTRUDING OBJECTS OR STANDING WITH THE SWING OF A DOOR. SEC. 1108.5.3

As per the design team's request, the site plan was revised to show the proposed improvements to the existing site. The improvements include the addition of a new entrance to the existing building, the addition of a new parking area, and the addition of a new landscaping area. The improvements are shown in the site plan and are consistent with the design team's request.

PARKING CALCULATION	
FROM TABLE 142-05F PARKING RATIOS FOR SPECIFIED NON-RESIDENTIAL USES	
BUSINESS & PROF.	3.3 SPACES/1000
GOVERNMENT BLDG.	3.3 SPACES/1000
4,344 SF. OFFICE AREA X 3.3/1000	14.5 SPACES REQUIRED
316 SF. OFFICE/STORAGE AREA X 3.3/1000	4 SPACES REQUIRED
AUTOMOBILE/SERVICE	
STATION (BUS SERVICE BAY)	1 SPACE/STATION
10 BUS SERVICE BAYS X 1 SPACE PER BAY	10 SPACES REQUIRED
TOTAL: 29 SPACES REQUIRED	
TOTAL: 73 SPACES PROVIDED*	
* CURRENT FACILITY IS ASPHALT PAVED RV SALES CENTER. PARKING SPACES PROVIDED FOR MTS/PUBLIC AGENCY EMPLOYEES AND VISITING PUBLIC AGENCY OFFICIALS. REMAINING SPACES SHOWN ARE FOR MTS/PUBLIC AGENCY PARA-TRANSIT (SMALL) BUS FLEET	


THE BRADLEY PROJECTS
architecture | interiors | urban design
4600 Kensington Drive
San Diego, CA 92116
(619) 546-4118
(619) 786-7499
www.bradleyprojects.com



MTS
7550 COPLEY PARK PLACE
(PREVIOUS HOLLAND MOTORS SALES CENTER)
SAN DIEGO, CA 92111
TENANT IMPROVEMENTS PHASE I

Project Number: 1103
Original Date: MARCH 2011
Phase: CD
Drawn: JUB
Checked: JUB
MARCH 2011
SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

Scale: 1/16" = 1'-0"
A
1.00
Sheet Number 00 OF 00



1 EXISTING SITE PLAN / PLOT PLAN
A1.00 FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT

SCALE: 1/16" = 1'-0"



EXISTING WINDOW SCHEDULE - FOR INFORMATION ONLY									
NO.	QTY	WINDOW SIZE (W X H)	TYPE	FINISH	GLAZING	ADDITIONAL NOTES	FIELD VERIFY ALL DIMENSIONS		
1	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
2	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
3	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
4	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
5	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
6	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
7	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
8	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
9	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			
10	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	BLACK-OUT FILM TO BE APPLIED PER MANUFACTURER'S SPECIFICATIONS			

1. WINDOW HARD AS TEMPERED. MUST BE SAFETY GLASS/TEMPERED PER 2007 CODE SECT. 2406.2.
2. CHECK BY ARCHITECT ALL FINISHES AND SHOP DRAWINGS.
3. ALL DOOR THRESHOLDS NOT TO EXCEED 1/2".

EXISTING DOOR SCHEDULE - FOR INFORMATION ONLY									
DOOR/DATE	QTY	DOOR SIZE	LEFT/RIGHT HANDING	MAX. THRESH. HGT.	RATED	TYPE/MATERIAL	GRADE	MISC. HARDWARE	GLAZING
1	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
2	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
3	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
4	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
5	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
6	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
7	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
8	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
9	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
10	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A

NEW DOOR SCHEDULE									
DOOR/DATE	QTY	DOOR SIZE	LEFT/RIGHT HANDING	MAX. THRESH. HGT.	RATED	TYPE/MATERIAL	GRADE	MISC. HARDWARE	GLAZING
1	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
2	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
3	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
4	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
5	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
6	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
7	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
8	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
9	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A
10	1	3'-0" X 7'-0"	VARIES	1/2"	NO	HOLLOW CORE / WTL.	PNT. GRD.	LOCKSET	N/A

1. GLAZING HARD AS TEMPERED. MUST BE SAFETY GLASS/TEMPERED PER 2007 CODE SECT. 2406.2.
2. CHECK BY ARCHITECT ALL FINISHES AND SHOP DRAWINGS.
3. ALL DOOR THRESHOLDS NOT TO EXCEED 1/2".

NEW WINDOW SCHEDULE									
WINDOW	QTY	WINDOW SIZE (W X H)	TYPE	FINISH	GLAZING	ADDITIONAL NOTES	FIELD VERIFY ALL DIMENSIONS		
1	1	3'-0" X 5'-0"	FIXED	ANODIZED ALUM. STOREFRONT	TEMPERED	FIXED, TEMPERED SAFETY GLASS (24X KAMMER, VISTA OR EQ.)			

FINISH SCHEDULE									
SPACE	FLOOR	BASE	WALLS				CEILING		REMARKS
DESIGNATION	FLOOR	BASE	EAST	SOUTH	WEST	NORTH	MATERIAL	HEIGHT	
TELECOM ROOM	VCT-1	VB-1	GWB	P-2	EXIST	P-2	EXIST	EXIST	(N) GWB
KITCHEN	VCT-1	VB-1	GWB	P-2	EXIST	P-2	EXIST	EXIST	REWORK SHOWER AREA PER PLAN FOR (N) H/W ROOM
TOILET 1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	PATCH ANY DAMAGED FINISHES RESULTING FROM DEMO FOR THE NEW RESTROOMS
TOILET 2 & 3	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	INSTALL NEW BRACKET LIGHT FIXTURE & EXHAUST FAN
TOILET 4 & 5	CT-1	CT-2	GWB	CT-1	GWB	CT-1	GWB	CT-1	DOOR INFILL REQUIRED @ RESTROOM
PROJECT MANAGER HALLWAY 1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
IT MANAGER	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
AGM	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
LOBBY HALLWAY 1	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	PROTECTED ADHESIVE VINYL SIGNAGE TO BE INSTALLED ON FRONT DOORS, CORRIDOR, W/ OWNER
FARE CLERK	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	(N) GYP BRD CEILING PER PLAN/DETAILS
PAYROLL CLERK	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	INFILL AT WINDOW OPENING, REPLACE ACT CEILING W/ GYP BRD. - METAL JOISTS
CUSTOMER SERVICE	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
SCHEDULING + RESERV.	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	NEW ALUM. + GLASS STOREFRONT SYSTEM @ ROLL-UP DOOR 6" C. TEXTURE WALLS
DISPATCH	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	SPRUE/PATCH (C) T-BAR CEILING, PROVIDE (N) ACTS AS NEEDED
PARA OPS	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
FR OPS	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
MAINT. MANAGER	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	
MAINT. CLERK	VCT-1	VB-1	EXIST	EXIST	EXIST	EXIST	EXIST	EXIST	

SELECTED FINISH SCHEDULE MATERIALS LEGEND									
DESIGNATION	MANUFACTURER / COMPANY	COLOR	STYLE	FINISH / PROD. #	SIZE	REP. / CONTACT	REMARKS		
P-1	(PAINT)	SHERWIN WILLIAMS	6530	REVEL BLUE	SEMI-GLOSS	--	--	--	--
P-2	(PAINT)	SHERWIN WILLIAMS	SW 7028	INCREDIBLE WHITE	SEMI-GLOSS	--	--	--	--
VCT-1	(VINYL COMP. TILE)	AZROCK	V-850	PEWTER GRAY	--	--	--	--	--
VCT-2	(VINYL COMP. TILE)	AZROCK	V-866	SHALE GRAY	--	--	--	--	--
VB-1	(VINYL BASE)	JOHNSONITE	CHARCOAL	--	--	--	--	--	--
CT-1	(CERAMIC TILE)	DAL TILE	ASH BLEND	KEYSTONE ELEMENTS	ED15	1" X 1"	SHONDA DAWSON (650) 571-1937	GROUT: CUSTOMS - DOVE GRAY #370	ALTERNATE: DAL TILE, COLOR SCHEME: BROWN, SLUDGE GRAY, EKE
CT-2	(CERAMIC TILE)	DAL TILE (WALL TILE, MATCHING W. FLOOR BASE & B. WALLS/DOORS)	DESERT GRAY	SEMI-GLOSS	X-114	6" X 6"	SHONDA DAWSON (650) 571-1937	GROUT: CUSTOMS - DOVE GRAY #370	ALTERNATE: DAL TILE, COLOR SCHEME: BROWN, SLUDGE GRAY, EKE
ACT-1	(ACQUST. CLING TILE)	MATCH EXISTING	--	--	--	--	--	--	--
PLASTIC LAMINATE FOR COUNTERS	WILSON ART	4623	GRAPHITE NEBULA	--	--	--	--	--	--

1. ALL IN SUPPLEMENT T-BAR/ACT CEILING TO COMPLY WITH CURRENT CODE SECT. 2406.2 (2" SEPARATE CODE CLIPS, ETC.)
2. PATCH/REPAIR/REPLACE WALLS AND PAINT FOR SCHEDULE. PATCH TEXTURE TO MATCH EXIST.
3. CLEAN (S) DOORS AND JAMS - NO PAINTING COATS OF NEW FOR (S) DOORS/JAMS.
4. REMOVE, CLEAN AND PAINT ALL JAMS/REGISTERS TO MATCH EXISTING FINISHES WITH SAME APPLICATION.
5. SCHEDULE ALL GYP BRD CEILING TILES FOR REUSE - REPAIR DAMAGED TILES WITH SCHEDULED TILES.
6. ALL COUNTERS TO BE PROFESSIONALLY CLEANED AT THE CONCLUSION OF CONSTRUCTION.

SCOPE OF WORK (1)

- (N) ROOF LADDER SECURITY COVER
- DEMO PARTITION WALL PER PLAN
- (N) PARTITION WALLS PER PLAN
- RELOCATE (E) WATER HEATER PER PLAN (NO PLUMBING ABOVE TELECOM ROOM)
- (N) GYP BRD CEILING IN TELECOM ROOM
- INSTALL (N) VISION GLASS IN HALLWAY DOOR CODE WOOD DOOR
- RELOCATE KITCHEN SINK, SINK/VAS/DRAIN/STOVE/MICROWAVE PER PLAN

SCOPE OF WORK (2)

- (N) ADA TOILET ROOMS PER PLAN
- (N) PARTITION WALLS PER PLAN
- (N) GYP BRD CEILING IN (N) TOILET ROOMS & FARE CLERK OFFICE
- (N) ALUMINUM FAL SURFACE MOUNTED AT ENTRY PER PLAN

SCOPE OF WORK (3)

- DEMO PARTITION WALL PER PLAN
- (N) PARTITION WALLS PER PLAN
- (N) GYP BRD CEILING IN PROJECT MANAGER OFFICE, SCHEDULING/RESERVATIONS & DISPATCH (POTENTIAL NETWORK CORDS)
- NEW STOREFRONT INFILL AT (E) OPENING PER PLAN (PROVIDE SHOP DRAWING FOR APPROVAL PRIOR TO FABRICATION)
- REMOVE METAL POSTS (GRIND SMOOTH) PER PLAN


LEGEND

- (N) WALL
- (N) PARTITION WALL
- (N) LOW PARTITION WALL
- (N) WALL ITEM FOR DEMO
- (N) PARTITION WALL (TYP. DETAIL) SEE 2406.1 FOR MORE INFORMATION
- (N) INFILL WALL (TYP. DETAIL) SEE 2406.1 FOR MORE INFORMATION
- (N) LOW PARTITION WALL (TYP. DETAIL) SEE 2406.1 FOR MORE INFORMATION

PLUMBING FIXTURE COUNT

FROM TABLE 4-1 CPC

OFFICE 200SF/OCCUPANT
4344 SF / 200 SF = 21.72
21.72 / 2 = 10.86
11 MALE AND 11 FEMALE
TOTAL REQUIRED: 22
2 MALE TOILETS, 2 FEMALE TOILETS
2 MALE LAVS, 2 FEMALE LAVS
TOTAL PROVIDED: 2 MALE TOILETS, 2 MALE LAVS
2 FEMALE TOILETS, 2 FEMALE LAVS
OK



1. PROPOSED NEW FLOOR PLAN - TENANT IMPROVEMENT PLAN
A2.04 FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT

THE BRADLEY PROJECTS
design
architecture interiors urban
4600 Kensington Drive
San Diego, CA 92116
(619) 548-4118
(619) 758-7481
www.thebradley.com



ARCHITECT
No. C 21182
Exp. 5/31/12
STATE OF CALIFORNIA

MTS
First America

7550 COPLEY PARK PLACE
(PREVIOUS HOLLAND MOTORS SALES CENTER)
SAN DIEGO, CA 92111
TENANT IMPROVEMENTS PHASE I


Project Number: 1103
Original Date: MARCH 2011
Phase: CD
Drawn: JJB
Checked: JJB
MARCH 2011

Scale: 1/4" = 1'-0"
A
2.04
Sheet Number 00 Of 00




FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT

SCALE: 1/2" = 1'-0"




FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT


SCALE: 1/2" = 1'-0"




LOW HEIGHT CUBICLE WALL




NEW PARTITION DETAIL AT ROOF



NEW GYP CEILING



PARTITION DOOR INFILL DETAIL



FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT SCALE: 1/2" = 1'-0"

FIRST AMERICA - MTS PARA TRANSIT TENANT IMPROVEMENT PROJECT

SCALE: 1" = 1'-0"



7550 COPLEY PARK PLACE
(PREVIOUS HOLLAND MOTORS SALES CENTER)

TENANT IMPROVEMENTS PHASE I

Project Number:	1103
Original Date:	MARCH 2011
Phase:	CD
Drawn:	JJB
Checked:	JJB

MARCH 2011

SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

Scale: 1/4" = 1'-0"

A
4.01
Sheet Number 00 Of 00

CERTIFICATE OF COMPLIANCE

(Page 2 of 4)

LTG-1C

Project Name:

FIRST TRANSIT

Date:

3-7-11

BOOK LIGHTING SCHEDULE and FIELD INSPECTION ENERGY CHECKLIST

Fill in entries for all spaces: a) area controls, b) multi-level controls, c) manual daylighting controls for daylight areas > 100 A2, automatic daylighting controls for daylight areas > 2,500 sq. ft. d) shut-off controls, e) display lighting controls, f) tailored lighting controls - general lighting controlled separately from display, ornamental and display case lighting and g) demand responsive automatic controls for retail stores > 35,000 sq. ft. in accordance with Section 111.

MANDATORY LIGHTING CONTROLS - FIELD INSPECTION ENERGY CHECKLIST

Type/Description	Number of Units	Location in Building	Special Features	Pass	Fail
OVERRIDE SWITCH	1	LOBBY DB		☒	☐

SPECIAL FEATURES INSPECTION CHECKLIST (See Page 2 of 4 of LTG-1C)

The local enforcement agency should pay special attention to the items specified in this checklist. These items require special written justification and documentation, and special verification. The local enforcement agency determines the adequacy of the justification, and may reject a building or design that otherwise complies based on the adequacy of the special justification and documentation submitted.

Field Inspector's Notes or Discrepancies:

2008 Nonresidential Compliance Forms

August 2009

CERTIFICATE OF COMPLIANCE

(Page 2 of 4)

LTG-1C

Project Name:

FIRST TRANSIT

Date:

3-7-11

Installation Certificate, LTG-1-INST (Retain a copy and verify form is completed and signed)

Field Inspector

Certificate of Acceptance, LTG-2A (Retain a copy and verify form is completed and signed)

Field Inspector

A separate Lighting Schedule must be filled out for Conditioned and Unconditioned Spaces installed Lighting Power listed on this Lighting Schedule is only for: ☒ CONDITIONED SPACE ☐ UNCONDITIONED SPACE

☒ The actual indoor lighting power listed below includes all installed permanent and portable lighting systems in accordance with §146(a).

☐ Only for spaces: Up to the first 0.2 watts per square foot of portable lighting shall not be required to be included in the calculation of actual indoor lighting power density in accordance with the Exception to §146(a). All portable lighting in excess of 0.2 watts per square foot is included below.

Luminaire Schedule (Type, Lamp, Ballast)

A	B	C	D	E	F	G	H
Name or Item Tag	Complete Luminaire Description (i.e. lamp, fluorescent ballast, fixture, and dimmable electronic ballast)	Watts per Luminaire	Number of Luminaire	Area (sq. ft.)	Number of Luminaire	Area (sq. ft.)	Field Inspector
A	2 x 4 FLUORESCENT 2-18 LAMPS	64	12	168			
B	1 x 4 FLUORESCENT 2-18 LAMPS	64	2	128			

Building total number of pages

1

Sum of all pages

896

1. Voltage shall be determined according to Section 1350 (and 4). Voltage shall be rising or light fixture, and name of each.

2. If Field then double on Page 2 of the Inspection Checklist Form and take appropriate action to correct. For building plans if necessary.

2008 Nonresidential Compliance Forms

August 2009

CERTIFICATE OF COMPLIANCE

(Page 1 of 4)

LTG-1C

Project Name:

FIRST TRANSIT

Date:

3-7-11

Project Address:

7550 COPLEY PARK PLACE

Climate Zone:

Building CFA: 924

San Diego, CA 92111

Unconditioned Floor Area: 0

General Information:

Building Type: ☒ Nonresidential ☐ High-Rise Residential ☐ Hotel/Motel

☒ Schools ☐ Public Schools ☐ Conditioned Spaces ☐ Unconditioned Spaces

Phase of Construction: ☒ New Construction ☐ Addition ☐ Alteration

Method of Compliance: ☒ Complete Building ☐ Area Category ☐ Tolerated

I certify that this Certificate of Compliance documentation is accurate and complete.

Department Author's Declaration Statement:

Name: Pervez Mobin, PE

Signature:

Date: 3-14-11

Company: Engineering Design Solutions, Inc.

Address: 10650 Scripps Ranch Blvd., #105

City/State/Zip: San Diego, CA 92131

Phone: (658) 530-0900

Principal Lighting Designer's Declaration Statement:

I am eligible under Division 3 of the California Business and Professions Code to accept responsibility for the lighting design.

This Certificate of Compliance identifies the lighting features and performance specifications required for compliance with Title 24, Pages 1 and 6 of the California Code of Regulations.

The design features represented on this Certificate of Compliance are consistent with the information provided to document this design on the other applicable compliance forms, schedules, calculations, plans and specifications submitted to the enforcement agency for approval with the building permit application.

Name: Pervez Mobin, PE

Signature:

Phone: (658) 530-0900

Company: Engineering Design Solutions, Inc.

Address: 10650 Scripps Ranch Blvd., Suite 106

City/State/Zip: San Diego, CA 92131

License # E14055

Date: 3-14-11

Lighting Mandatory Measures

Indicate location on building plans of Mandatory Measures Note Block:

LIGHTING COMPLIANCE FORMS & WORKSHEETS (check box if worksheet is included)

For detailed instructions on the use of this and all Energy Efficiency Standards compliance forms, please refer to the Nonresidential Manual published by the California Energy Commission.

LTG-1C Pages 1 through 4. Certificate of Compliance. All Pages required on plans for all submissions.

LTG-2C Lighting Controls Credit Worksheet

LTG-3C Indoor Lighting Power Allowance

LTG-4C Pages 1 through 4 Tolerated Method Worksheet

LTG-5C Pages 1 through 4 Line Voltage Track Lighting Worksheet

2008 Nonresidential Compliance Forms

August 2009

CERTIFICATE OF COMPLIANCE

(Page 4 of 4)

LTG-3C

Project Name:

FIRST TRANSIT

Date:

ALLOWED LIGHTING POWER (Enter One Method)

A Separate LTG-3C must be filled out for Conditioned and Unconditioned Spaces. Indoor Lighting Power Allowances listed on this page are only for: ☒ UNCONDITIONED spaces ☐ UNCONDITIONED spaces

COMPLETE BUILDING METHOD

BUILDING CATEGORY (from Table 146-F)	WATTS PER (sq. ft.)	COMPLETE WATTS	ALLOWED WATTS
DEVICE	1150	0.85	978
TOTALS		3150	978

AREA CATEGORY METHOD - Part A

AREA CATEGORY (from Table 146-F)	WATTS PER (sq. ft.)	AREA (sq. ft.)	ALLOWED WATTS
TOTALS			

AREA CATEGORY METHOD - Part B

Primary Function	Area	Watts per sq. ft.	Watts	Watts per sq. ft.	Watts
TOTALS					

TOLERATED METHOD

Tolerated Watts using the Tolerated Method taken from LTG-4C (page 1 of 4) Row 3

The indoor lighting power allowance using the Tolerated Method of compliance shall be determined using the LTG-4C on all forms. A separate set of LTG-4C forms shall be filled out for CONDITIONED and UNCONDITIONED spaces.

2008 Nonresidential Compliance Forms

August 2009

CERTIFICATE OF COMPLIANCE

(Page 4 of 4)

LTG-1C

Project Name:

FIRST TRANSIT

Date:

Conditioned and Unconditioned space Lighting must not be combined for compliance

Indoor Lighting Power for Conditioned Spaces

From Conditioned (LTG-1C Page 2)	Watts	From Unconditioned (LTG-1C Page 3)	Watts
Unrelated Lighting	896	Unrelated Lighting	
Lighting Control Credit		Lighting Control Credit	
Conditioned Spaces (from LTG-2C)		Unrelated Spaces (from LTG-2C)	
Adjusted Installed Lighting Power	896	Adjusted Installed Lighting Power	
Complies if installed < Allowed		Complies if installed < Allowed	

Allowed Lighting Power

Conditioned Spaces (from LTG-3C)

978

Unconditioned Spaces (from LTG-3C)

Enforcement Agency:

This form is to be used by the designer and attached to the plans. Listed below is the acceptance test for the lighting system.

LTG-2A: The designer is required to check the acceptance tests and list all tested devices serving the building or space that is certified as meeting the Acceptance Requirements for Code Compliance. If all the lighting system in a certain type requires a test, list the different lighting and the number of systems. The NAB System in the Appendix of the Nonresidential Reference Agreement Manual describes the test. These test forms will be part of the plan, completion of this section will allow the responsible party to budget for the scope of work appropriately. Forms can be grouped by type of luminaire controlled.

Enforcement Agency:

Special Acceptance: Written Acceptance Permit is granted for a newly constructed building or space or when new lighting systems with controls is installed in the building or space shall be certified as meeting the Acceptance Requirements.

The LTG-2A form is not intended as a complete form and is not to be accepted by the enforcement agency unless the device is checked and is filled and signed. In addition, a Certificate of Acceptance form shall be submitted to the enforcement agency containing plans, specifications, installation certificate, and operating and maintenance information with the requirements of §10-10(b) of Title 24 Part 6. The field worksheet must require the property filled out and signed before the building can receive final occupancy. A copy of the LTG-2A for each different lighting luminaire control(s) must be provided to the enforcement of the building for their records.

Luminaire Controlled

Equipment Rooming Tables	Description	Location	Comply and Sensors and Automatic Daylighting Controls
L.V. CONTROL PANEL	TYPE A,B, D1,D2, C,E,F,F1, H,H1,I,J,K	1	☐

2008 Nonresidential Compliance Forms

August 2009

MANDATORY MEASURES

(VS) BUILDING LIGHTING SHUT-OFF

The building lighting shut-off system consists of an automatic line switch, with a zone for each floor.

(VS) OVERRIDE FOR BUILDING LIGHTING SHUT-OFF

The automatic building shut-off system is provided with a manual accessible override switch in sight of the lights. The area of the override is not to exceed 5,000 square feet.

(VS) AUTOMATIC CONTROL DEVICES CERTIFIED

All automatic control devices specified are certified, all alternate equipment shall be certified and installed as directed by the manufacturer.

(VS) FLUORESCENT BALLAST AND LUMINAIRES CERTIFIED

All fluorescent ballasts subject to certification and specified for the projects are certified.

(VS) INDIVIDUAL ROOM/AREA CONTROLS

Each room and area in this building is equipped with a separate switch or occupancy sensor device for each area with floor-to-ceiling walls.

(VS) UNIFORM REDUCTION FOR INDIVIDUAL ROOMS

All rooms are areas greater than 100 square feet and more than 18 watts per square foot of lighting load shall be controlled with ballast-level ballasting for uniform reduction of lighting within the room.

(VS) DAYLIT AREA CONTROL

All rooms that are greater than 250 square feet and contain windows and skylights, the area for the effective use of daylight in the area shall have 50% of the lighting power in each daylight area controlled by a separate switch or the effective use of daylight throughout cannot be accomplished because the windows are continuously shaded by building on the adjacent lot. Diagram of shading during different times of year is included on plans.

2008 Nonresidential Compliance Manual

March 2008

LIGHTING FIXTURE SCHEDULE									
SYMBOL	LAMP			FIXTURE		BALLAST TYPE	MOUNTING	CATALOG NO.	REMARK
	QTY.	TYPE	WATTS	COLOR TEMP.	INPUT VOLTS				
A	2	T8	32	3500	120	64	ELECTRONIC	RECESSED	LIGHTOLIER CAT#PR52GRVA 232-120V
A2	2	T8	32	3500	120	64	ELECTRONIC	RECESSED	LIGHTOLIER CAT#PR52GRVA 232-120V W/90 MINUTE EMERGENCY BALLAST
B	2	T8	32	3500	120	64	ELECTRONIC	RECESSED	LIGHTOLIER CAT#BE1 W232UNVH1-120V

FIRST TRANSIT
7550 COPLEY PARK PLACE
San Diego, California 92111

Project Number:

Original Date:

Phase:

Drawn:

Checked:

BLDG. SEPT. SUBMITTAL 03-15-11

SHEET SIZE: 42" x 30"

DO NOT SCALE DRAWINGS

TITLE 24 AND LIGHT

FIXTURE SCHEDULE

E

2.00


Sheet Number

Of 00

© 2007, The Bradley Projects, Inc. All drawings and specifications are property of the architect and shall not be reproduced in any manner without expressed written permission from The Bradley Projects, Inc.

KEY NOTES


- 1 MAIN DISTRIBUTION BOARD 600A 208/120V EXISTING.
- 2 PANEL A 100A 208/120V EXISTING.
- 3 PANEL B 200A 208/120V EXISTING.
- 4 PANEL C 200A 208/120V EXISTING.
- 5 200A 208/120V 4P FUTURE ATS.
- 6 EXISTING 2" C WITH TELEPHONE SERVICE CABLE TO REMAIN.
- 7 EXISTING 110 BLOCK AND LIGHTNING PROTECTION TO REMAIN.
- 8 3/4" C-2#12H+2#12H+1#12EG.
- 9 INSTALL BRANCH CIRCUIT HORIZONTALLY IN LOW WALL.
- 10 INSTALL 3/4" C AND J-BOX FOR TEL/DATA OUTLET, STUBB CONDUIT 6" ABOVE CEILING.
- 11 NEW COPPER GROUND BUS 1/4" X 4" X 24", CONNECT TO EXISTING UFER GROUNDING USING BARE #4/0 COPPER WIRE.
- 12 LOCATION OF EXISTING UFER GROUNDING.
- 13 3/4" C-3#12H+3#12H+1#12EG.
- 14 30A/2P DISCONNECT MENA 3R.
- 15 FAN COOL UNIT (WALL MOUNTED).
- 16 CONDENSOR UNIT PAD MOUNTED.



2 FLOOR PLAN - ELECTRICAL NEW WORK
SCALE: 1/4" = 1'-0"

KEY NOTES

- 1 MAIN DISTRIBUTION BOARD 600A 208/120V EXISTING.
- 2 PANEL A 100A 208/120V EXISTING.
- 3 PANEL B 200A 208/120V EXISTING.
- 4 PANEL C 200A 208/120V EXISTING.
- 5 EXISTING RECEPTACLE AND TEL/DATA OUTLET TO BE DISCONNECTED AND REMOVED.
- 6 EXISTING RECEPTACLE AND TEL/DATA IN THESE ROOMS TO REMAIN U/S/N.



1 FLOOR PLAN - ELECTRICAL DEMO
SCALE: 1/4" = 1'-0"

THE BRADLEY PROJECTS
Architecture + Planning + Development
4800 Kensington Drive
San Diego, CA 92118
(619) 548-5181
(619) 788-7488 f
www.bradpl.com


Engineering Design Solutions Inc.
10550 Torrey Pines Drive, Suite 100
San Diego, California 92121
(619) 594-7300
www.edsn.com

FIRST TRANSIT
7550 COPLEY PARK PLACE
San Diego, California 92111

Project Number: 010101
Original Date: MAR 2011
Revised: 01
Drawn: EW
Checked: PW
BIDS SEPT. SUBMITTAL (9/15/11)
SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

ELECTRICAL FLOOR PLAN
DEMOLITION AND NEW
WORK


E
2.01
Sheet Number 01 00



2 REFLECTED CEILING PLAN - ELECTRICAL NEW WORK
SCALE: 1/4" = 1'-0"



- KEY NOTES**
- 1 NEW SWITCH. WIRE TO EXISTING LIGHTING FIXTURE.
 - 2 NEW SWITCH. WIRE TO NEW LIGHT FIXTURE.
 - 3 NEW SWITCH. WIRE TO NEW EXHAUST FAN.
 - 4 CONNECT TO EXISTING CIRCUIT.
- GENERAL NOTES**
- 1 INSTALL LIGHTING CONTACTOR TO CONTROL ALL LIGHTING CIRCUITS.
 - 2 INSTALL OVERRIDE SWITCH IN LOBBY OR



1 REFLECTED CEILING PLAN - ELECTRICAL DEMO
SCALE: 1/4" = 1'-0"



- KEY NOTES**
- 1 EXISTING FIXTURES TO BE DISCONNECTED AND REMOVED. CIRCUIT TO BE RE-USED.
 - 2 EXISTING WALL SWITCHES TO BE DISCONNECTED AND REMOVED.
 - 3 EXISTING FIXTURE TO REMAIN BUT RE-SWITCHED.

THE BRADLEY PROJECTS
Architecture + Planning + Development
4800 Kensington Drive
San Diego, CA 92116
(619) 546-5181
www.bradproj.com

Engineering Decision Solutions Inc.
10435 S. Highway 163, Suite 100
San Diego, California 92128
Tel: 619/593-0700
www.decisionsolutions.com

FIRST TRANSIT
7530 COPLEY PARK PLACE
San Diego, California 92111

Project Number: 2001-01
Original Date: MAR 2001
Drawn: EY
Checked: PM
SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

REFLECTED CEILING PLAN
DEMOLITION AND NEW
WORK

E
2.02
Sheet Number 01 00

PLUMBING FIXTURE SCHEDULE									
SYMBOL	DESCRIPTION	ROUGH-IN CONNECTION					REMARKS		
		HW (IN)	CW (IN)	W (IN)	TRAP (IN)	V (IN)			
WC-1	WATER CLOSET	=	3/4"	4	INTEGRAL	2"	AMERICAN STANDARD 293B-D12 CADET ADA VITREOUS CHINA, 1.6 GALLONS PER FLUSH ELONGATED SIPHON JET WATER CLOSET WITH CLOSE-COUPLED TANK WITH BOLT CAPS AND OLDSWITE OPEN SEAT WITH COVER AND CHECK HINGES.		
L-1	LAVATORY	1/2"	1/2"	2	1 1/2	1 1/2"	AMERICAN STANDARD 0335-D27 LUCERNE ADA MOUNT, VITREOUS CHINA WALL HUNG 20X18 LAVATORY. FAUCET TO BE SHOWN 5-66-G-H SELF CLOSING METERING TYPE WITH 4" SPOUT.		
FD-1	FLOOR DRAIN	=	1/2" TRAP PRIMER	2	2	2"	ZURN-ZN-415-P-5-B CAST IRON BODY WITH BOTTOM OUTLET FLOOR DRAIN AND 5" DIAMETER BRONZE STRAINER (ADJUSTABLE) DRAIN TO HAVE 1/2" TRAP PRIME CONNECTION		

- SPECIFICATIONS
- HOT WATER, COLD WATER DRAIN PIPING SHALL BE TYPE "L" COPPER TUBING WITH WROUGHT COPPER FITTINGS WITH 95-5 BRAZED JOINTS, LEAD FREE.
 - WASTE AND VENT PIPING SHALL BE SERVICE WEIGHT CAST IRON NO-HUB PIPING WITH NEOPRENE AND STAINLESS STEEL COUPLINGS.
 - BALL VALVES SHALL BE INBCO 585Y FULL PORT THREE PIECE VALVES.
 - INSULATION FOR HOT WATER AND DRAIN SHALL BE JOHNS-MANVILLE NSJ WITH SELF SEALING TAB.

- PLUMBING NOTES
- AREA SEPARATION WALLS:
A. WHERE PLUMBING PENETRATES AN AREA SEPARATION WALL SURFACE, THE SECTION PASSING THROUGH THE WALL SURFACE AND THE FIXTURE CONNECTIONS ATTACHED THERETO SHALL BE ONLY OF METAL.
 - SLOPE OF PIPING SYSTEMS:
SANITARY SEWER, WASTE & VENT PIPING: 2 % UNLESS NOTED OTHERWISE.
 - DOMESTIC HOT & COLD WATER STERILIZATION SHALL BE PER CPC 609.9
 - ALL PIPING SHALL BE SEISMICALLY BRACED/ANCHORED
 - ENTIRE INSTALLATION SHALL COMPLY WITH 2010 CALIFORNIA PLUMBING CODE (CPC)
 - WATER HEATER SHALL BE ANCHORED OR STRAPPED TO RESIST HORIZONTAL DISPLACEMENT DUE TO EARTHQUAKE MOTION PER SECTION 508.2 CPC.
 - TOILETS SHALL BE ULTRALOW FLUSH TYPE (1.6 GPF MAX).
 - EACH FAUCET SHALL NOT EXCEED A WATER FLOW OF 2.2 GPM.

- FIRE MARSHAL NOTES
- ALL ELECTRICAL AND PLUMBING SYSTEM PENETRATIONS THROUGH RATED ASSEMBLIES SHALL BE FIRE-STOPPED WITH AN APPROVED MATERIAL AS PRESCRIBED IN USC STANDARD 7-5. SEAL WITH AN APPROVED FIRE STOPPING COMPOUND OF I.C.B.O. #1697 OR APPROVED EQUAL. WHERE SERVICES PENETRATE AN AREA SEPARATION WALL, THE SECTION PASSING THRU THE WALL SURFACE AND THE FIXTURE CONNECTIONS THERETO SHALL BE ONLY OF METAL.
 - ALL PENETRATIONS THROUGH FIRE RATED WALLS, FLOORS AND CEILINGS SHALL BE SEALED WITH A MATERIAL CAPABLE OF PREVENTING THE PASSAGE OF HOT GASES WHEN SUBJECTED TO THE REQUIREMENTS OF A.S.T.M. E-814 AND AS PRESCRIBED IN USC STD. 7-5.

PLUMBING LEGEND			
SYMBOL	DESCRIPTION	ABBREV.	DESCRIPTION
(E) —	EXISTING PIPING	ABV	ABOVE
	REMOVE EXISTING PIPING ON FIXTURE	ADA	AMERICAN DISABILITY ACT
----	SANITARY OR WASTE BELOW GRADE	AFP	ABOVE FINISHED FLOOR
----	SANITARY OR WASTE ABOVE GRADE (ALL SANI)	AFG	ABOVE FINISHED GRADE
----	VENT (V)	AP	ACCESS PANEL
----	DOMESTIC COLD WATER (CW)	BFG	BELOW FINISHED GRADE
----	DOMESTIC HOT WATER (HW)	CLG	CEILING
CA	COMPRESSED AIR (CA)	CONN	CONNECT, CONNECTION
D+	SHUTOFF VALVE (SOV)	CONTR	CONTRABE
O	PIPE-UP UNLESS OTHERWISE NOTED	COORD	COORDINATE
C	PIPE DROP UNLESS OTHERWISE NOTED	DN	DOWN
LOW / HIGH	DROP OR RISE	DR	DRAIN
Q	TOP CONNECTION	DWG	DRAWINGS
Q	BOTTOM CONNECTION	ELDG	ELECTRICAL
Q	WALL CLEANOUT (PIPING AT CLG) (WCO)	EQUIP	EQUIPMENT
Q	FLOOR CLEANOUT (BURIED PIPING) (FCO)	EXIST.	EXISTING
Q	GRADE CLEANOUT (GGO)	FLR	FLOOR
Q	TRAP	FT	FOOT, FEET
Q	VALVE AND CAPPED OUTLET	FU	FIXTURE UNIT
Q	POINT OF CONNECTION	GPF	GALLON PER FLUSH
		GPM	GALLONS PER MINUTE
		GPH	GALLONS PER HOUR
		HDR	HEADER
		HP	HORSEPOWER
		HZ	HERTZ
		IE	INVERT ELEVATION
		IN	INCH
		INT	INTERVAL
		MAX	MAXIMUM
		MIN	MINIMUM
		NTS	NOT TO SCALE
		PSI	POUNDS PER SQUARE INCH
		POC	POINT OF CONNECTION
		POD	POINT OF DISCONNECTION
		SF	SQUARE FEET
		TYP	TYPICAL
		VTR	VENT THRU ROOF
		W	WITH

THE
BRADLEY
PROJECTS

Architecture + Planning + Development

4600 Kensington Drive
San Diego, CA 92116
(619) 548-5181
(619) 738-7488
www.bradpl.com

Engineering
Design
Solutions Inc.

10500 Scripps Ranch Blvd., Suite 105
San Diego, California 92131
Tel: 619-594-0000 Fax: 619-594-8999
www.bradpl.com

11-TBP-01

FIRST TRANSIT
7550 COPLEY PARK PLACE
San Diego, California 92111


Project Number:
Original Date: MAR 2011
Project:
Drawn: EW
Checked: PM

BLOG SEPT. SUBMITTAL 03-14-11

Sheet Size: 42" x 30"
DO NOT SCALE DRAWINGS


PLUMBING NOTES,
SYMBOLS,
ABBREVIATIONS, AND
FIXTURE SCHEDULE

P
1.00
Sheet Number Of 00




1 PLUMBING FLOOR PLAN - DEMOLITION
SCALE: 3/16" = 1'-0"






**THE
BRADLEY
PROJECTS**
Architecture + Planning + Development
(619) 558-5181
4600 Kensington Drive



2 ENLARGED PLUMBING FLOOR PLAN NEW WORK
SCALE: 1/4" = 1'-0"



1 ENLARGED PLUMBING FLOOR PLAN - DEMOLITION
SCALE: 1/4" = 1'-0"



SECTION 15200

PLUMBING TENANT IMPROVEMENT

PART 1 GENERAL

1.01 GENERAL NOTES

- A. Division 1 is a part of this section and the contract for this work, and applies to this section fully as if repeated herein.

1.02 SCOPE

- A. The work under this section includes everything necessary for and incidental to executing and completing the plumbing work, except as hereinafter specifically excluded.
- B. Work included shall be as indicated on the drawings, including but not limited to the following:
1. Sanitary Soil, Waste and Vent system.
 2. Domestic Hot and Cold Water System.
 3. Plumbing Fixtures and Equipment.
 4. Compressed air system.
 5. Vehicle washer piping.
 6. Waste oil piping.

1.03 SUBSTITUTIONS

- A. Substitutions shall be made in accordance with Division 1.

1.04 SUBMITTALS

- A. Submittals shall be made in accordance with Division 1 and shall include items listed under paragraph 1.02.B.

1.05 CODES AND STANDARDS

- A. All work and materials shall be in full accordance with the latest rules and regulations of the Fire Marshal; the Safety Orders of the Division of Industrial Safety; the California Electric Code; the California Plumbing Code; the California Mechanical Code; other applicable codes; laws or regulations of agencies lawfully empowered and having jurisdiction over this project. Nothing in the plans or specifications is to be construed to permit work not conforming to these codes.

1.06 PERMITS

- A. Contractor shall obtain all permits and licenses that are required for the performing of his work by all laws, ordinances, rules and regulations or orders of any officer and/or body, shall give all notices necessary in connection therewith, and pay all fees, charges, taxes and expenses incurred on account thereof. No work shall be covered before inspection by the jurisdictional inspection and the Architect.

1.07 CUTTING AND PATCHING

- A. Perform all cutting and fitting required for work of this section in rough construction of the building.
- B. All patching of finished construction of building shall be performed under the sections of specifications covering these materials.
- C. All patching of existing surfaces shall match existing materials and finished.

1.08 GENERAL

- A. Unless otherwise specified herein, all equipment and fixtures shall be installed in accordance with the manufacturers recommendations.
- B. Before submitting his bid, the Contractor for the work under this section shall carefully study all drawings, and shall make a careful examination of the premises. He shall definitely determine in advance, the methods of installing and connecting the apparatus, the means to be provided for getting any equipment into place, and shall make himself thoroughly familiar with all the requirements of the contract. After award of the contract, no subsequent allowances will be made with the above requirements and any other conditions affecting the installation and completion of all work.
- C. Workmanship: All labor shall be carefully skilled for this kind of work, thorough and first class in all respects and under the direction of a competent foreman.
- D. Special Note: Any work called for on plans shall be installed whether or not mentioned in these specifications.

1.09 DAMAGE BY LEAKS

- A. Contractor shall be responsible for damage to the grounds, walks, roads, buildings, piping systems, electrical systems and their equipment and contents, caused by leaks in the piping system being installed or having been installed herein. He shall repair at his expense all damage so caused. All repair work shall be done as directed by the Architect.

1.10 EMERGENCY REPAIRS

- A. The Owner reserves the right to make emergency repairs as required to keep equipment in operation without voiding the Contractor's guarantee bond nor relieving the Contractor of his responsibilities.

1.11 EXPLANATION AND PRECEDENCE OF DRAWINGS

- A. For purposes of clearness and legibility, drawings are essentially diagrammatic, and, although size and location of equipment are drawn to scale wherever possible, Contractor shall make use of all data in all the contract documents and shall verify this information at building site.
- B. The drawings indicate required size and points of termination of pipes, and suggest proper routes to conform to structure, avoid obstructions and preserve clearances. However, it is not intended that drawing indicate all necessary offsets, and it shall be the work of the Contractor to make the installation in such a manner as to conform to structure, avoid obstructions, preserve headroom and keep opening and passageways clear, without further instructions or cost to the Owner.
- C. It is intended that all apparatus be located symmetrical with architectural elements. Refer to architectural details in completing the correlating work.
- D. The Contractor shall fully inform himself regarding any and all peculiarities and limitations of the spaces available for the installation of all work and materials furnished and installed under the contract. He shall exercise due and particular caution to determine that all parts of his work are made quickly and easily accessible.
- E. The Contractor shall study all drawings and specifications to determine any conflict with ordinances and statutes. Any errors or omissions shall be reported, and any changes shall be shown in pre-as-built drawings and the additional work performed at no cost to the Owner.
- F. Submittal of bid shall indicate the Contractor has examined the site and drawings and has included all required allowances in his bid. No allowance shall be made for any error resulting from Contractor's failure to visit job site and to review drawings, and bid shall include costs for all required drawings and changes as outlined above, all at no cost to Owner.

1.12 SUPERVISION AND COOPERATION

- A. Contractor shall include the services of experienced superintendents for each sub-section who shall be constantly in charge of the work, together with the qualified journeymen, helpers and laborers, required to properly uncoil, install, connect, adjust, start and operate and test the work involved, including equipment and materials furnished by others are by the Owner.
- B. The work under this section shall be in cooperation with the work of other trades to prevent conflict or interference and to aid rapid completion of the overall project.

1.13 OPERATION

- A. The Owner may require operation of parts or all of the installation for beneficial occupancy prior to final acceptance. Refer to General Conditions of the Contract.
- B. Cost of utilities for such operation shall be paid by the Owner. Said operation shall not be construed as acceptance of the work.

1.14 UTILITY SERVICES DURING CONSTRUCTION

- A. All water and electrical power used for construction shall be paid for by the contractor.

PART 2 PRODUCTS

2.01 FITTINGS AND PIPING

- A. All domestic water piping and compressed air piping: above grade, type L" copper tubing, hard drawn with wrought copper fittings, and silver soldered joints.
- B. Waste and vent piping shall be hot-dip galvanized steel with stainless steel and neoprene type couplings.
- C. Waste oil and vehicle washer piping: Seamless galvanized steel piping and fittings.

2.02 VALVES AND FITTINGS

- A. Angle Stops
1. Eastman 74RLK-SBI
 2. Ball valves
 3. Shall be NIBCO 585Y fullport style.

2.03 PLUMBING FIXTURES

- A. General Requirements
1. Provide new fixtures, approved, free from flaws and blemished, with finished surfaces clear, smooth and bright.
 2. Visible parts of fixture brass and accessories shall be heavily chrome plated.
 3. Fixtures shall be product of one manufacturer. Fitting of same type shall be products of one manufacturer.
 4. Protect fixtures against use and damage during construction.
- B. Job Conditions

1. Confirm location and size of fixtures and opening before rough-in and installation.
2. Plumbing fixture trim and exposed supplies and waste shall be brass with polished chrome plated finish. Individual loose key stops, or so specified, screw driver stops, shall be provided for all supplies, and unless integral with valves or faucet, unless otherwise approved by Architect, shall be mounted under the fixture. Exposed supplies and wastes to wall shall be provided with polished chrome plated cast brass wall escutcheons.
3. Supplies shall be with loose key stops and flexible risers.
4. Traps above floor shall be cast brass "P" traps with bronze nuts unless otherwise indicated.

- C. Reference is made to American Standard, it is understood to mean that equivalent fixtures as manufactured by Kohler Company are acceptable if used throughout. See Fixture Schedule on drawings.

PART 3 EXECUTION

3.01 PIPE INSTALLATION

- A. Joints in copper tubing shall be made by first thoroughly cleaning the surface of the pipe and fittings, applying flux and sweating with solder.
- B. Pipe shall be carefully cleaned before installation. The ends of threaded pipe shall be reamed out full size with a long taper reamer so as to be partially bell-mouthed and perfectly smooth.
- C. Flush out all water mains and sanitary drains with water so as to obtain free flow. Remove all obstructions and defects discovered. Remove and relay any sections and pipe already laid and found to be defective or which has had grade or joints disturbed.
- D. Openings in pipes, drains fittings apparatus and equipment shall be kept covered or plugged to prevent foreign substance from entering.
- E. Run piping free to traps, sags, or bonds. Grade and valve for complete drainage and control of the system.
- F. All piping to be run to maintain headroom and keep passageways and openings clear. Run parallel and straight with adjacent walls or ceilings to present a uniform appearance.
- G. All piping, except where noted otherwise on plans shall be concealed in walls or above ceilings.
- H. Bending or forcing of pipe will not be allowed. Use fittings for all offsets or changes in alignment of piping.
- I. Proper provision shall be made for expansion and contraction by means of fittings and anchors and supports of all piping.
- J. Street elbows, bushings and long screw fittings will not be allowed.
- K. Unions shall be installed after each screw-type valve, connections for all equipment, appliances and as required for erection and maintenance. No unions shall be installed in concealed location.
- L. Install isolation unions on all connections between dissimilar metals (galvanized steel, black steel to copper).
- M. No holes for pipe or equipment will be allowed in any structural member without written consent of the Architect. Where pipes are to pass through or interfere with any member, or where notching, boring or cutting of the structure is necessary the work shall be done by the General Contractor as directed by the Architect.
- N. The Contractor shall, at a time in advance of the work, furnish instructions to the General Contractor as to his requirements for openings, recesses, and chases in the walls, partitions, framing or openings. Should furnishing this information be neglected, delayed or incorrect and additional cutting is found to be required, the costs of same shall be charged to the Contractor.
- O. Provide and install polished chromium plate brass floor, ceiling or wall plates for all pipes, exposed in finished portions of the buildings.
- P. All scales and figure dimensions are approximate and are given for estimate purposes only. Before proceeding with any work, this Contractor shall carefully check and verify all dimensions, sizes, and shall assume full responsibility to other parts of the equipment and to the structure.
- Q. Any minor changes in work, which has not been installed, shall be made by this Contractor without additional compensation, except changes which are caused by architectural revisions, which increase or decrease the size of the materials specified or indicated on the drawings. This Contractor shall submit an estimate of the cost of or credit for such changes he does not consider of a minor nature and shall proceed only upon the written authority of the Architect.
- R. All piping shall be isolated from other piping, any part of the building, framing or conduit with 1" sleeves of hot-dip galvanized steel or pipe isolators.

3.02 FIXTURE INSTALLATION

- A. All plumbing fixtures shall be caulked and caulked along joint at counter tops, and other intersecting surfaces with white silicone.

3.03 REQUIREMENTS FOR ACCEPTANCE

- A. All of the following items must be completed prior to final inspections. No exception will be made and no final payment will be made until all items are completed.
- B. Thoroughly clean all parts of the piping, valves, and equipment. Exposed parts which are to be painted shall be thoroughly cleaned of cement, plaster, and other materials and oil and grease spots shall be removed. Such surfaces shall be carefully wiped and all cracks and corners scraped out.
- C. Exposed metal work shall be carefully brushed down with steel brushes to remove rust and other spots left smooth and clean. Trap elements shall be removed during cleaning and flushing period, after which they shall be replaced and adjusted.
- D. All domestic hot and cold water lines shall be sterilized with chlorine, the chlorine residual concentration shall indicate not less than 50 parts per million and shall be retained for a period of not less than twenty-four (24) hours. All work and certification of performance must be done by qualified personnel.

3.04 TEST AND ADJUSTMENTS

- A. No piping work, fixtures, or equipment shall be concealed or covered until they have been inspected and approved by the Engineer, who shall be notified when the work is ready for inspection. All work shall be completely installed, tested as required by this section and the State Ordinances and State Safety Orders, and shall be leak-tight before inspection is requested. All tests shall be repeated upon request to the satisfaction of those making the inspection.
- B. All domestic water piping shall be flushed out, tested at two times the working system pressure and shall be left under pressure of supply main or minimum of 40 PSI for the balance of the construction period. No air testing allowed.

	Type of System Test Medium (lbs. Per sq. inches)	Gauge Pressure
Soil, Waste, and Vent Piping within Building	Minimum of 10' head of each joint for duration of check of three hours minimum, with no loss in head	Water
Domestic Water & Vehicle Washer Piping	Two times the working pressure	Water
Compressed Air Piping	1 1/2 times the working pressure	Compressed air
Waste Oil Piping		
C.	Test pressure in pounds per square inch, or inches of vacuum, gauge, are given as initial pressure to be applied to lines being tested, together with test medium.	
D.	Tests are to be applied for minimum period of twenty-four (24) hours and until test are complete.	
E.	Final pressure at the end of the test period shall be no more nor less than that caused by expansion or contraction of the test medium due to temperature changes.	

3.05 DRAWINGS OF RECORD

- A. In addition to the reproducible "as-built" required, two complete sets of blue line plumbing drawings will be provided for the purpose of showing a complete picture of the work as actually installed. These drawings shall serve as work progress report sheets and the Contractor shall make all notations, neat and legible, thereon daily as the work proceeds. The drawings shall be available for inspection at all times and shall be kept at the job at a location designated by the Architect. At completion of the work, these as-built drawings shall be signed by the Contractor indicating his approval, dated and returned to the Architect.
- D. The dimensional location of all concealed piping shall be accurately recorded on the "as-built" drawings.

END OF SECTION



FIRST TRANSIT
7550 COPLEY PARK PLACE
San Diego, California 92111

Project Number:	
Original Date:	MAR 2011
Phase:	
Drawn:	EW
Checked:	PH
REVISIONS	
NO. 1	REVISION
NO. 2	REVISION
NO. 3	REVISION
NO. 4	REVISION
NO. 5	REVISION
NO. 6	REVISION
NO. 7	REVISION
NO. 8	REVISION
NO. 9	REVISION
NO. 10	REVISION
NO. 11	REVISION
NO. 12	REVISION
NO. 13	REVISION
NO. 14	REVISION
NO. 15	REVISION
NO. 16	REVISION
NO. 17	REVISION
NO. 18	REVISION
NO. 19	REVISION
NO. 20	REVISION
NO. 21	REVISION
NO. 22	REVISION
NO. 23	REVISION
NO. 24	REVISION
NO. 25	REVISION
NO. 26	REVISION
NO. 27	REVISION
NO. 28	REVISION
NO. 29	REVISION
NO. 30	REVISION
NO. 31	REVISION
NO. 32	REVISION
NO. 33	REVISION
NO. 34	REVISION
NO. 35	REVISION
NO. 36	REVISION
NO. 37	REVISION
NO. 38	REVISION
NO. 39	REVISION
NO. 40	REVISION
NO. 41	REVISION
NO. 42	REVISION
NO. 43	REVISION
NO. 44	REVISION
NO. 45	REVISION
NO. 46	REVISION
NO. 47	REVISION
NO. 48	REVISION
NO. 49	REVISION
NO. 50	REVISION
NO. 51	REVISION
NO. 52	REVISION
NO. 53	REVISION
NO. 54	REVISION
NO. 55	REVISION
NO. 56	REVISION
NO. 57	REVISION
NO. 58	REVISION
NO. 59	REVISION
NO. 60	REVISION
NO. 61	REVISION
NO. 62	REVISION
NO. 63	REVISION
NO. 64	REVISION
NO. 65	REVISION
NO. 66	REVISION
NO. 67	REVISION
NO. 68	REVISION
NO. 69	REVISION
NO. 70	REVISION
NO. 71	REVISION
NO. 72	REVISION
NO. 73	REVISION
NO. 74	REVISION
NO. 75	REVISION
NO. 76	REVISION
NO. 77	REVISION
NO. 78	REVISION
NO. 79	REVISION
NO. 80	REVISION
NO. 81	REVISION
NO. 82	REVISION
NO. 83	REVISION
NO. 84	REVISION
NO. 85	REVISION
NO. 86	REVISION
NO. 87	REVISION
NO. 88	REVISION
NO. 89	REVISION
NO. 90	REVISION
NO. 91	REVISION
NO. 92	REVISION
NO. 93	REVISION
NO. 94	REVISION
NO. 95	REVISION
NO. 96	REVISION
NO. 97	REVISION
NO. 98	REVISION
NO. 99	REVISION
NO. 100	REVISION

PLUMBING
SPECIFICATIONS

P
5.00
Sheet Number Of 00

CERTIFICATE OF COMPLIANCE AND FIELD INSPECTION ENERGY CHECKLIST

Project Name: _____ Date: 8/25/2018 Client Name: _____

Inspector: Don Brown

ENV-101
(Page 2 of 4)


SYSTEM/PRODUCT (See Row 1)

Product is the building material or the CMF certified, the building material exposed, concrete to be formed. Exposed Formwork or Performance Equivalent.


OVER ALL COMPLIANCE ☒ **YES** ☐ **NO** ☐ **NOT SURE**

Item	Pass	Fail	NA
1. Compliance with California Green Building Code (California Green Building Code 15.01.01.01, 15.01.01.02, 15.01.01.03, 15.01.01.04, 15.01.01.05, 15.01.01.06, 15.01.01.07, 15.01.01.08, 15.01.01.09, 15.01.01.10, 15.01.01.11, 15.01.01.12, 15.01.01.13, 15.01.01.14, 15.01.01.15, 15.01.01.16, 15.01.01.17, 15.01.01.18, 15.01.01.19, 15.01.01.20, 15.01.01.21, 15.01.01.22, 15.01.01.23, 15.01.01.24, 15.01.01.25, 15.01.01.26, 15.01.01.27, 15.01.01.28, 15.01.01.29, 15.01.01.30, 15.01.01.31, 15.01.01.32, 15.01.01.33, 15.01.01.34, 15.01.01.35, 15.01.01.36, 15.01.01.37, 15.01.01.38, 15.01.01.39, 15.01.01.40, 15.01.01.41, 15.01.01.42, 15.01.01.43, 15.01.01.44, 15.01.01.45, 15.01.01.46, 15.01.01.47, 15.01.01.48, 15.01.01.49, 15.01.01.50, 15.01.01.51, 15.01.01.52, 15.01.01.53, 15.01.01.54, 15.01.01.55, 15.01.01.56, 15.01.01.57, 15.01.01.58, 15.01.01.59, 15.01.01.60, 15.01.01.61, 15.01.01.62, 15.01.01.63, 15.01.01.64, 15.01.01.65, 15.01.01.66, 15.01.01.67, 15.01.01.68, 15.01.01.69, 15.01.01.70, 15.01.01.71, 15.01.01.72, 15.01.01.73, 15.01.01.74, 15.01.01.75, 15.01.01.76, 15.01.01.77, 15.01.01.78, 15.01.01.79, 15.01.01.80, 15.01.01.81, 15.01.01.82, 15.01.01.83, 15.01.01.84, 15.01.01.85, 15.01.01.86, 15.01.01.87, 15.01.01.88, 15.01.01.89, 15.01.01.90, 15.01.01.91, 15.01.01.92, 15.01.01.93, 15.01.01.94, 15.01.01.95, 15.01.01.96, 15.01.01.97, 15.01.01.98, 15.01.01.99, 15.01.02.01, 15.01.02.02, 15.01.02.03, 15.01.02.04, 15.01.02.05, 15.01.02.06, 15.01.02.07, 15.01.02.08, 15.01.02.09, 15.01.02.10, 15.01.02.11, 15.01.02.12, 15.01.02.13, 15.01.02.14, 15.01.02.15, 15.01.02.16, 15.01.02.17, 15.01.02.18, 15.01.02.19, 15.01.02.20, 15.01.02.21, 15.01.02.22, 15.01.02.23, 15.01.02.24, 15.01.02.25, 15.01.02.26, 15.01.02.27, 15.01.02.28, 15.01.02.29, 15.01.02.30, 15.01.02.31, 15.01.02.32, 15.01.02.33, 15.01.02.34, 15.01.02.35, 15.01.02.36, 15.01.02.37, 15.01.02.38, 15.01.02.39, 15.01.02.40, 15.01.02.41, 15.01.02.42, 15.01.02.43, 15.01.02.44, 15.01.02.45, 15.01.02.46, 15.01.02.47, 15.01.02.48, 15.01.02.49, 15.01.02.50, 15.01.02.51, 15.01.02.52, 15.01.02.53, 15.01.02.54, 15.01.02.55, 15.01.02.56, 15.01.02.57, 15.01.02.58, 15.01.02.59, 15.01.02.60, 15.01.02.61, 15.01.02.62, 15.01.02.63, 15.01.02.64, 15.01.02.65, 15.01.02.66, 15.01.02.67, 15.01.02.68, 15.01.02.69, 15.01.02.70, 15.01.02.71, 15.01.02.72, 15.01.02.73, 15.01.02.74, 15.01.02.75, 15.01.02.76, 15.01.02.77, 15.01.02.78, 15.01.02.79, 15.01.02.80, 15.01.02.81, 15.01.02.82, 15.01.02.83, 15.01.02.84, 15.01.02.85, 15.01.02.86, 15.01.02.87, 15.01.02.88, 15.01.02.89, 15.01.02.90, 15.01.02.91, 15.01.02.92, 15.01.02.93, 15.01.02.94, 15.01.02.95, 15.01.02.96, 15.01.02.97, 15.01.02.98, 15.01.02.99, 15.01.03.01, 15.01.03.02, 15.01.03.03, 15.01.03.04, 15.01.03.05, 15.01.03.06, 15.01.03.07, 15.01.03.08, 15.01.03.09, 15.01.03.10, 15.01.03.11, 15.01.03.12, 15.01.03.13, 15.01.03.14, 15.01.03.15, 15.01.03.16, 15.01.03.17, 15.01.03.18, 15.01.03.19, 15.01.03.20, 15.01.03.21, 15.01.03.22, 15.01.03.23, 15.01.03.24, 15.01.03.25, 15.01.03.26, 15.01.03.27, 15.01.03.28, 15.01.03.29, 15.01.03.30, 15.01.03.31, 15.01.03.32, 15.01.03.33, 15.01.03.34, 15.01.03.35, 15.01.03.36, 15.01.03.37, 15.01.03.38, 15.01.03.39, 15.01.03.40, 15.01.03.41, 15.01.03.42, 15.01.03.43, 15.01.03.44, 15.01.03.45, 15.01.03.46, 15.01.03.47, 15.01.03.48, 15.01.03.49, 15.01.03.50, 15.01.03.51, 15.01.03.52, 15.01.03.53, 15.01.03.54, 15.01.03.55, 15.01.03.56, 15.01.03.57, 15.01.03.58, 15.01.03.59, 15.01.03.60, 15.01.03.61, 15.01.03.62, 15.01.03.63, 15.01.03.64, 15.01.03.65, 15.01.03.66, 15.01.03.67, 15.01.03.68, 15.01.03.69, 15.01.03.70, 15.01.03.71, 15.01.03.72, 15.01.03.73, 15.01.03.74, 15.01.03.75, 15.01.03.76, 15.01.03.77, 15.01.03.78, 15.01.03.79, 15.01.03.80, 15.01.03.81, 15.01.03.82, 15.01.03.83, 15.01.03.84, 15.01.03.85, 15.01.03.86, 15.01.03.87, 15.01.03.88, 15.01.03.89, 15.01.03			

[illegible]



MECHANICAL FLOOR PLAN - DEMOLITION
SCALE: 1/4"=1'-0"



THE BRADLEY PROJECTS
Architecture + Planning + Development
(619) 546-5161
www.bradleyprojects.com
4500 Kensington Drive
San Diego, CA 92116




FIRST TRANSIT
7550 COPLEY PARK PLACE
San Diego, California 92111




Project Number: _____
Original Date: MAR 2011
Phase: _____
Drawn: EW
Checked: PM
SUBMITTAL 03-09-11
SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

FLOOR PLAN - DEMO
M4.1
Sheet Number Of 00



MECHANICAL ZONING PLAN
SCALE: 1/4"=1'-0"



THE BRADLEY PROJECTS
Architecture + Planning + Development
4600 Kensington Drive
San Diego, CA 92116
(619) 549-5161
(866) 788-7488
www.bradleyprojects.com

11-118P-01
11-118P-01
11-118P-01
11-118P-01

FIRST TRANSIT
7350 COPLEY PARK PLACE
San Diego, California 92111

ABBOTT ENGINEERING
www.abbotteng.com

Project Number: _____
Original Date: MAR 2011
Phase: _____
Drawn: EW
Checked: PM

SUBMITTAL 03-09-11

SHEET SIZE: 42" x 30"
DO NOT SCALE DRAWINGS

ZONING PLAN

M3.1

Sheet Number Of 00

© 2007, The Bradley Projects, Inc. All drawings and specifications are property of the architect and shall not be reproduced in any manner without expressed written permission from The Bradley Projects, Inc.